

WR-28-72

COLORADO DIVISION OF WATER RESOURCES

101 Columbine Bldg., 1845 Sherman St.
Denver, Colorado 80203

RECEIVED

THIS FORM MUST BE SUBMITTED
WITHIN 60 DAYS OF COMPLETION
OF THE WORK DESCRIBED HERE-
ON. TYPE OR PRINT IN BLACK
INK.

WELL COMPLETION AND PUMP INSTALLATION REPORT

PERMIT NUMBER 65970

WATER RESOURCES
STATE ENGINEER

WELL OWNER William H. Volz NE 5 % of the SE 6 % of Sec. 6

ADDRESS 6925 West 5th Ave., Lakewood, Colo. T 5 S 9 R 71 W 6th P.M.

DATE COMPLETED 2/3/73 1973

HOLE DIAMETER
8 in. from 0 to 20 ft.
6 in. from 20 to 450 ft.
_____ in. from _____ to _____ ft.

WELL LOG

From	To	Type and Color of Material	Water Log
0'	5'	Gravel	
5'	22'	Granite brown (decomposed)	
22'	140'	Granite gray	
140'	178'	Granite gray quartz	water
178'	225'	Granite gray fract.	
225'	248'	Granite quartz	
248'	250'	Quartz dry	
250'	300'	Granite gray	
300'	388'	Granite gray quartz	
388'	400'	Granite gray	
400'	431'	Granite gray	
431'	435'	Quartz	water
435'	450'	Blue granite	

TOTAL DEPTH 450'

Use additional pages necessary to complete log.

CASING RECORD: Plain Casing

Size 6 5/8 & kind Steel from 0 to 20 ft.
Size 1 1/2 & kind Plastic from 10 to 140 ft.
Size 1 1/2 & kind Plastic from 178 to 431 ft.
4 1/2 Plastic 445 450

Perforated Casing

Size 4 1/2 & kind Plastic from 140 to 178 ft.
Size 4 1/2 & kind Plastic from 431 to 445 ft.
Size _____ & kind _____ from _____ to _____ ft.

GROUTING RECORD

Material Cement
Intervals 0' 20' Solid
Placement Method Poured in

GRAVEL PACK: Size _____
Interval _____

TEST DATA

Date Tested 2/3/73 1973
Static Water Level Prior to Test 90 ft.
Type of Test Pump blown by air
Length of Test 1 hr
Sustained Yield (Metered) 2 1/2 GPM
Final Pumping Water Level 445'

PUMP INSTALLATION REPORT

Pump Make _____

Type _____

Powered by _____ HP _____

Pump Serial No. _____

Motor Serial No. _____

Date Installed _____

Pump Intake Depth _____

Remarks _____

WELL TEST DATA WITH PERMANENT PUMP

Date Tested _____


Static Water Level Prior to Test _____

Length of Test _____ Hours

Sustained yield (Metered) _____ GPM

Pumping Water Level _____

Remarks _____



CONTRACTORS STATEMENT

The undersigned, being duly sworn upon oath, deposes and says that he is the contractor of the well or pump installation described hereon; that he has read the statement made hereon; knows the content thereof, and that the same is true of his own knowledge.

Signature James Drilling Co. James Drilling License No. 343

State of Colorado, County of Jefferson SS

Subscribed and sworn to before me this 13 day of April, 19 73

My Commission expires: October 1, 19 76

Notary Public Steve Keaton

FORM TO BE MADE OUT IN QUADRUPPLICATE: WHITE FORM must be an original copy on both sides and signed. WHITE AND GREEN copies must be filed with the State Engineer. PINK COPY is for the Owner and YELLOW COPY is for the Driller.